

# AWWA Practice Test Questions and Answers

## 1. What does AWWA stand for in water management?

- A) American Water Works Association
- B) Advanced Water Waste Analysis
- C) Automated Water Works Authority
- D) Association for Water and Wastewater

## 2. What is the maximum contaminant level (MCL) for lead in drinking water according to EPA standards?

- A) 0.005 mg/L
- B) 0.015 mg/L
- C) 0.025 mg/L
- D) 0.050 mg/L

## 3. Which water treatment process removes dissolved minerals and salts?

- A) Filtration
- B) Chlorination
- C) Reverse osmosis
- D) Sedimentation

## 4. What is the recommended chlorine residual level in distribution systems?

- A) 0.1-0.2 mg/L
- B) 0.2-0.5 mg/L
- C) 0.5-1.0 mg/L
- D) 1.0-2.0 mg/L

Answers: 1-A 2-B 3-C 4-B

For More AWWA Questions and Answers FREE, AWWA Online Prep Training, AWWA Exam, AWWA Study Guide, AWWA Flashcards, AWWA Quizzes visit:

**AWWA Practice Test**