

CCN1 Practice Test Questions and Answers

1. What does a gas tightness test confirm?

- A) That the gas installation pipework contains no leaks — confirmed by applying a test pressure and observing for pressure drop
- B) That the pipework is correctly sized for the appliance load
- C) That the correct gas pressure is reaching the appliances
- D) That all appliances are correctly commissioned

2. RIDDOR stands for which of the following?

- A) Reporting of Injuries, Diseases and Dangerous Occurrences Regulations
- B) Registration of Industrial Defects, Damages and Official Reports
- C) Regulation of Installation, Design and Domestic Operations Review
- D) Repair of Internal Damage, Defects and Operational Risks

3. What is the purpose of a gas meter bypass?

- A) It is not a legitimate installation component — a bypass around a gas meter is illegal as it allows gas use without metering
- B) It allows gas to continue during meter maintenance
- C) It is a pressure regulator fitted parallel to the meter
- D) It is a safety valve that diverts gas during excess pressure events

4. When must a decommissioning purge be carried out?

- A) Before any gas pipework is cut, disconnected, or opened for work — to displace gas with air or inert gas and prevent ignition during work
- B) Only before major renovation work
- C) Only for commercial gas installations
- D) Only when pipework is being permanently abandoned

Answers: 1-A 2-A 3-A 4-A

For More CCN1 Questions and Answers FREE, CCN1 Online Prep Training, CCN1 Exam, CCN1 Study Guide, CCN1 Flashcards, CCN1 Quizzes visit:

CCN1 Practice Test