

# CPD Practice Test Questions and Answers

## 1. What is a Class I standpipe system designed for?

- A) Fire department use only, with 2.5-inch hose connections for trained firefighters
- B) Occupant use with 1.5-inch hose stations for building inhabitants
- C) Combined use by both occupants and the fire department
- D) Automatic activation without manual operation by any personnel

## 2. What is a deluge sprinkler system and when is it used?

- A) A system where all sprinklers are open and water flows simultaneously when the deluge valve opens, used in high-hazard areas
- B) A system that uses antifreeze solution to protect piping in freezing environments
- C) A system where individual sprinklers open only when their fusible element melts
- D) A system limited to residential occupancies per NFPA 13R requirements

## 3. What is the main purpose of a sanitary drainage system?

- A) To provide clean water to the building
- B) To remove wastewater and sewage from buildings safely
- C) To reduce the amount of water used in the building
- D) To increase the number of water fixtures

## 4. Why is venting important in a sanitary drainage system?

- A) To regulate the temperature of wastewater
- B) To allow proper air circulation and prevent siphoning of traps
- C) To reduce the size of pipes
- D) To filter out debris from wastewater

**Answers: 1-A 2-A 3-B 4-B**

For More CPD Questions and Answers FREE, CPD Online Prep Training,  
CPD Exam, CPD Study Guide, CPD Flashcards, CPD Quizzes visit:

## CPD Practice Test