

Certified Electrical Inspector Practice Test Questions and Answers

1. According to the NEC, what is the minimum height requirement for electrical service equipment installation?

- A) 5 feet
- B) 6 feet
- C) 6.5 feet
- D) 8 feet

2. What is the maximum allowable voltage drop for branch circuits under normal conditions?

- A) 3%
- B) 5%
- C) 8%
- D) 10%

3. Which type of electrical fault presents the greatest fire hazard?

- A) Short circuit
- B) Ground fault
- C) Arc fault
- D) Overload

4. What is the required working space clearance in front of electrical panels rated 600V or less?

- A) 2 feet
- B) 3 feet
- C) 4 feet
- D) 6 feet

Answers: 1-C 2-B 3-C 4-B

For More Certified Electrical Inspector Questions and Answers FREE, Certified Electrical Inspector Online Prep Training, Certified Electrical Inspector Exam, Certified Electrical Inspector Study Guide, Certified Electrical Inspector Flashcards, Certified Electrical Inspector Quizzes visit:

Certified Electrical Inspector Practice Test

Practice Test Geeks © All Rights Reserved