

ESCO A2L Practice Test Questions and Answers

1. Before storing A2L cylinders, which key factor must be verified?

- A) That cylinders are horizontal
- B) That cylinders are completely empty
- C) Proper upright position in ventilated area
- D) That cylinders are painted black

2. What does the A2L classification indicate about the refrigerant?

- A) Highly flammable and toxic
- B) Low toxicity and low flammability
- C) Non-flammable and non-toxic
- D) Corrosive and reactive

3. Why is proper labeling of A2L refrigerant systems required by code?

- A) To promote brand recognition
- B) For internal sales tracking
- C) To warn of refrigerant flammability
- D) To track refrigerant odor levels

4. How must recovered A2L refrigerants be handled according to EPA rules?

- A) Vented outdoors immediately
- B) Stored indefinitely without documentation
- C) Reused without cleaning
- D) Reclaimed or disposed according to EPA standards

Answers: 1-C 2-B 3-C 4-D

For More ESCO A2L Questions and Answers FREE, ESCO A2L Online Prep Training, ESCO A2L Exam, ESCO A2L Study Guide, ESCO A2L Flashcards, ESCO A2L Quizzes visit:

ESCO A2L Practice Test