

Gas Pipe Technician Practice Test Questions and Answers

1. What is the maximum allowable pressure for residential natural gas service lines?

- A) 2 psi
- B) 5 psi
- C) 10 psi
- D) 15 psi

2. Which type of pipe is NOT approved for natural gas installations?

- A) Black steel pipe
- B) CSST (Corrugated Stainless Steel Tubing)
- C) PVC pipe
- D) Copper tubing (approved for specific applications)

3. What is the proper method for testing gas line joints for leaks?

- A) Using a match or open flame
- B) Soap bubble solution or electronic leak detector
- C) Listening for hissing sounds only
- D) Visual inspection only

4. What is the minimum burial depth for residential gas service lines?

- A) 12 inches
- B) 18 inches
- C) 24 inches
- D) 36 inches

Answers: 1-B 2-C 3-B 4-B

For More Gas Pipe Technician Questions and Answers FREE, Gas Pipe Technician Online Prep Training, Gas Pipe Technician Exam, Gas Pipe Technician Study Guide, Gas Pipe Technician Flashcards, Gas Pipe Technician Quizzes visit:

Gas Pipe Technician Practice Test

Practice Test Geeks © All Rights Reserved