

# Water Treatment Operator Certification Practice Test Questions and Answers

**1. What is the primary purpose of coagulation in water treatment?**

- A) To kill bacteria and viruses
- B) To remove dissolved minerals
- C) To bind small particles together for easier removal
- D) To adjust pH levels

**2. What is the ideal pH range for drinking water distribution systems?**

- A) 5.5 - 6.5
- B) 6.5 - 8.5
- C) 8.5 - 9.5
- D) 9.5 - 10.5

**3. Which chemical is commonly used for disinfection in water treatment plants?**

- A) Aluminum sulfate
- B) Sodium chloride
- C) Chlorine
- D) Calcium carbonate

**4. What does turbidity measure in water quality testing?**

- A) The amount of dissolved oxygen
- B) The clarity or cloudiness of water
- C) The pH level
- D) The chlorine residual

Answers: 1-C 2-B 3-C 4-B

For More Water Treatment Operator Certification Questions and Answers FREE, Water Treatment Operator Certification Online Prep Training, Water Treatment Operator Certification Exam, Water Treatment Operator Certification Study Guide, Water Treatment Operator Certification Flashcards, Water Treatment Operator Certification Quizzes visit:

**Water Treatment Operator Certification Practice Test**